

Essential Requirements
for
IP Terminal of NGS Division

Scope

This document lays down the essential requirements for **IP Terminal /SIP Terminal** or IP Phone or an equivalent device based on the SIP Protocol under Mandatory Testing & Certification of Telecommunication Equipment (MTCTE) notified by Government of India vide Gazette Notification no. G.S.R. 113 (E) dated 5th September 2017.

The document also defines the necessary testing requirements for certification under the MT&CTE framework.

Following are the variants under **IP Terminal**.

Name of Equipment	Variant 1
IP Terminal	Only one variants named " SIP Terminal "

History

Sno.	Name of ER	ER Number	Remark
1.	IP Terminal	TEC/ER/NGS/IPT-001/01/APR-2018	ISSUE 01

SECTION I

(A) Electromagnetic Compatibility (EMC) Requirements

The equipment shall conform to the EMC requirements as per the following standards and limits indicated therein. (Category -Class : B)

Sr. No	Requirements	Testing requirements
i.	<p>Conducted and radiated emission (applicable to telecom equipment): Name of EMC Standard: "CISPR 22 (2008) or CISPR 32 (2015) - Limits and methods of measurement of radio disturbance characteristics of Information Technology Equipment". Limits:-</p> <ul style="list-style-type: none"> i. To comply with Class B of CISPR 22 (2008) or CISPR 32 (2015). ii. The values of limits shall be as per TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16. iii. For Radiated Emission tests, limits below 1 GHz shall be as per Table 4 (a) or 5 (a) for measuring distance of 10m or Table 4(a1) or 5(a1) for measuring distance of 3m. 	<p>Test results from Designated CAB of TEC to be submitted for compliance.</p>
ii.	<p>Immunity to Electrostatic discharge: Name of EMC Standard: IEC 61000-4-2 {2008} "Testing and measurement techniques of Electrostatic discharge immunity test". Limits: -</p> <ul style="list-style-type: none"> i. Contact discharge level 2 {± 4 kV} or higher voltage; ii. Air discharge level 3 {± 8 kV} or higher voltage; <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p> <p>Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	<p>Test results from Designated CAB of TEC to be submitted for compliance.</p>

<p>iii.</p>	<p>Immunity to radiated RF: Name of EMC Standard: IEC 61000-4-3 (2010) "Testing and measurement techniques-Radiated RF Electromagnetic Field Immunity test".</p> <p>Limits:- For Telecom Equipment and Telecom Terminal Equipment with Voice interface (s) i. Under Test level 2 {Test field strength of 3 V/m} for general purposes in frequency range 80 MHz to 1000 MHz and ii. Under test level 3 (10 V/m) for protection against digital radio telephones and other RF devices in frequency ranges 800 MHz to 960 MHz and 1.4 GHz to 6.0 GHz.</p> <p>For Telecom Terminal Equipment without Voice interface (s) Under Test level 2 {Test field strength of 3 V/m} for general purposes in frequency range 80 MHz to 1000 MHz and for protection against digital radio telephones and other RF devices in frequency ranges 800 MHz to 960 MHz and 1.4 GHz to 6.0 GHz.</p> <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p> <p>Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	<p>Test results from Designated CAB of TEC to be submitted for compliance.</p>
<p>iv.</p>	<p>Immunity to fast transients (burst): Name of EMC Standard: IEC 61000- 4- 4 {2012) "Testing and measurement techniques of electrical fast transients/burst immunity test"</p> <p>Limits:- Test Level 2 i.e. a) 1 kV for AC/DC power lines; b) 0.5 kV for signal / control / data / telecom lines;</p> <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	<p>Test results from Designated CAB of TEC to be submitted for compliance.</p>

	Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.	
v.	<p>Immunity to surges: Name of EMC Standard: IEC 61000-4-5 (2014) "Testing & Measurement techniques for Surge immunity test"</p> <p>Limits:- i. For mains power input ports: (a) 2 kV peak open circuit voltage for line to ground coupling (b) 1 kV peak open circuit voltage for line to line coupling ii. For telecom ports: (a) 2 kV peak open circuit voltage for line to ground (b) 2 kV peak open circuit voltage for line to line coupling.</p> <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p> <p>Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	Test results from Designated CAB of TEC to be submitted for compliance.
vi.	<p>Immunity to conducted disturbance induced by Radio frequency fields: Name of EMC Standard: IEC 61000-4-6 (2013) "Testing & measurement techniques-Immunity to conducted disturbances induced by radio- frequency fields"</p> <p>Limits:- Under the test level 2 {3 V r.m.s.} in the frequency range 150 kHz-80 MHz for AC / DC lines and Signal /Control/telecom lines.</p> <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p> <p>Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	Test results from Designated CAB of TEC to be submitted for compliance.

vii.	<p>Immunity to voltage dips & short interruptions (applicable to only ac mains power input ports, if any): Name of EMC Standard: IEC 61000-4-11 (2004) "Testing & measurement techniques- voltage dips, short interruptions and voltage variations immunity tests"</p> <p>Limits:-</p> <ul style="list-style-type: none"> i. a voltage dip corresponding to a reduction of the supply voltage of 30% for 500ms (i.e. 70 % supply voltage for 500ms) ii. a voltage dip corresponding to a reduction of the supply voltage of 60% for 200ms; (i.e. 40% supply voltage for 200ms) iii. a voltage interruption corresponding to a reduction of supply voltage of > 95% for 5s. iv. a voltage interruption corresponding to a reduction of supply voltage of >95% for 10ms. <p>Performance Criteria shall be as per Table 1 under Clause 6 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p> <p>Applicable Performance Criteria shall be as per Table 3 under Clause 7.2 of TEC Standard No. TEC/SD/DD/EMC-221/05/OCT-16.</p>	Test results from Designated CAB of TEC to be submitted for compliance.
viii.	<p>Immunity to voltage dips & short interruptions (applicable to only DC power input ports, if any): Name of EMC Standard: IEC 61000-4-29:2000: Electromagnetic compatibility (EMC)-PART 4-29: Testing & measurement techniques- voltage dips, short interruptions and voltage variations on d.c. input power port immunity tests.</p> <p>Limits:-</p> <ul style="list-style-type: none"> i. voltage Interruption with 0% of supply for 10ms. Applicable Performance Criterion shall be B. ii. voltage Interruption with 0% of supply for 30ms, 100ms, 300ms and 1000ms. 	Test results from Designated CAB of TEC to be submitted for compliance.

	<p>Applicable Performance Criterion shall be C.</p> <p>iii. voltage dip corresponding to 40% & 70% of supply for 10ms, 30ms. Applicable Performance Criterion shall be B.</p> <p>iv. voltage dip corresponding to 40% & 70% of supply for 100ms, 300ms and 1000ms. Applicable Performance Criterion shall be C.</p> <p>v. voltage variations corresponding to 80% & 120% of supply for 100ms to 10s as per table 1c of IEC 61000-4-29. Applicable Performance Criterion shall be B.</p>	
--	---	--

Note-1: For checking compliance with the above EMC requirements, the method of measurements shall be in accordance with TEC Standard No. TEC/SD/RD/EMC-002/02.OCT.2016 and the references mentioned therein.

Note-2: Amendment if any will be incorporated as and when notified by Radio Division

SECTION II

(B) Safety Requirements

Sr. No	Requirements	Testing requirements
i.	The equipment shall conform to IS 13252 part 1: 2010 "Information Technology Equipment – Safety- Part 1: General Requirements" [equivalent to IEC 60950-1 {2005} "Information Technology Equipment –Safety- Part 1: General Requirements" or IEC 62368]	Test results from Designated CAB of TEC to be submitted for compliance.

Note-1: Amendment if any will be incorporated as and when notified by Radio Division

SECTION III

(C) Technical Requirements

Technical Requirements of equipment & its variants are mentioned in the table.

Remark

- 1) For all RFC mentioned in this ER, Conformance testing report is must for the all clauses of that RFC mentioned in this ER.
- 2) Dual stack or IPV6 shall become mandatory from the day DOT notifies its mandatory implementation policy.

Table 1: List of Interfaces for products and their variants(OPTIONAL)

Applicable to→ Interface↓	IP Terminal / SIP Terminal
10/100 BASE-T Ethernet Electrical Interface	Y
10/100/1000 BASE-T Ethernet Electrical Interface	Y
1 GE Optical Ethernet Interface	Y

Table 2: List of Test Parameters Applicable to Interfaces and their international standards

Applicable to→ Test Parameter↓	Standard	10/100 BASE-T Ethernet Electrical Interface	10/100/1000 BASE-T Ethernet Electrical Interface	1 GE Optical Ethernet Interface
Link speed test	802.3	Y*	Y*	
Duplex(Full or Half)	IEEE 802.3 (Clause no. 28)	Y*	Y*	
Auto Negotiation	IEEE 802.3 (Clause no. 28)	Y*	Y*	
Optical output power	802.3			Y*
Operating Wavelength	802.3			Y*
Receiver Sensitivity	802.3			Y*

***will be modified as per IT division inputs**

Table 3: List of Test Parameters Applicable to product variants and their international standards

Applicable to→ Test Parameter↓	Standard	SIP Terminal
Addressing dual stack or IPv6	For Dual Stack: RFC 4213 or For IPv6: RFC 2460	Y
SIP	RFC 3261	Y
TCP	RFC 793	Y
RTP	RFC 3550	Y
RTCP	RFC 3551	Y

SIP	RFC 3261
SIP Header : Message Body Type	RFC 3261 (Clause no.7.4.1)
Generating SIP request (To, R-URI, From, Call-ID, CSeq, Max-Forwards, Via)	RFC 3261 (Clause no.8.1.1, 8.1.1.2 to 8.1.1.7)
SIP Dialog and Transaction	RFC 3261 (Clause no.12. 12.1.1, 12.1.2)
SIP Terminating a Session with a BYE request.	RFC 3261 (Clause no. 15)
SIP Creating the initial invite	RFC 3261 Clause no.13.2.1)
User Authentication	RFC 3261 (Clause no. 21)
RTP	3550
RTP Version and Port	RFC 3550 (Clause no. 5.1)
RTP : Sender report RTCP packet version	RFC 3550 (Clause no. 6.4.1)
RTP : Payload Type	RFC 3550 (Clause no. 5.1)
RTP : Sequence number	RFC 3550 (Clause no. 5.1)
RTP : SSRC Identification	RFC 3550 (Clause no. 5.1)
RTCP	RFC 3551
Registering Additional Encodings	RFC 3551 (Clause no. 3)
Guidelines for sample based audio encodings	RFC 3551 (Clause no. 4.3)
Guidelines for sample based audio encodings	RFC 3551 (Clause no. 4.4)
GSM-EFR	RFC 3551 (Clause no. 4.5.9)
Port Assignment	RFC 3551 (Clause no. 8)
TCP	RFC 793
Header Format	RFC 793 (Clause no. 3.1)
Terminology	RFC 793 (Clause no. 3.2)
Sequence numbers	RFC 793 (Clause no. 3.3)
IPV6	RFC 2460
Header: Version Field	RFC 2460 (Clause no. 3)
Header: Traffic Class	RFC 2460 (Clause no. 3)
Header: Flow Label	RFC 2460 (Clause no. 3)
Header: Payload Length	RFC 2460 (Clause no. 3)
Header: No next header after IPv6 Header	RFC 2460 (Clause no. 3)
Header: Hop Limit	RFC 2460 (Clause no. 3)
Header: Source and Destination Address	RFC 2460 (Clause no. 3)
Dual stack	RFC 4213
Dual IP layer operation	RFC 4213 (Clause no. 2.1)
Dual IP layer operation: DNS	RFC 4213 (Clause no. 2.2)

SECTION IV

(D) Other Requirements

SECTION V

(E) Security Requirements

As per Security Requirements finalized by Security Wing of DoT HQ.